



# ST LAWRENCE ENGINEERING DPC

745 GRAVES STREET, CLAYTON NEW YORK 13624  
315/783.6384 • 315/408.7443  
www.fourthcoast.com - www.stlawrenceengineering.com

**Town of Clayton**  
**Upper Landing on Grindstone Island Boat Launch**

Addendum No. 3  
12 November 2021

This addendum is to be included in and made part of the Contract Documents.

## Contract Drawings

1. **Reference Contract Drawings:**
  - A. **CLARIFICATION:** The following scale to the sheets listed below.
    - S1 Existing Site Plan – 1" = 30'
    - S2 Existing Site Plan Enlarged – 1" = 10'
    - S3 Demolition Plan – 1" = 20'
    - S4 Proposed Site Plan Enlarged – 1" = 30'
    - S5 Proposed Site Plan Enlarged – 1" = 10'
  
2. **Reference Contract Drawing S5 Proposed Site Plan Enlarged:**
  - A. **ADD** the following:
    1. The concrete Abutments and sloping concrete approach pads shall receive 2 layers of #5 rebar 12" OC Each way.

Respectfully,

ST. LAWRENCE ENGINEERING DPC

Robert J. Company, PE

Cc: Lance Peterson, Supervisor, Town of Clayton  
Augusta Withington, Fourth Coast, Inc.